



Power Transmission Corporation of Uttarakhand Ltd.

पावर ट्रांसमिशन कारपोरेशन ऑफ उत्तराखण्ड लि०

7 - B, Lane - 1, Vasant Vihar Enclave
Dehradun - 248001

Mob. 9837893749
Telefax - 0135-2763429

No. 4/4/SE(QA/QC)/PTCUL

Dated: 16/08/2012

M/s. Gemscab Industries Ltd.

40, Rajasthani Udyog Nagar,
G.T. Karnal Road, Delhi - 110033
Tel: 011 - 42151572
Fax: 011 - 45136501
E-mail: gemscab@vsnl.com

Subject:-Regarding vendor approval for supply of HT Power Cables, LT Power & Control Cables (upto 132 KV Projects) in PTCUL.

Dear Sir,

Please refer your letter no. G-CAB/D-ANP dated 03.11.2011, for vendor registration in PTCUL. In this connection, your works was inspected on 17.06.2012 by undersigned and your credentials were evaluated. It is to inform you that your vendor registration has been accepted by PTCUL and you are being registered as a vendor for the supply of HT Power Cables, LT Power & Control Cables (upto 132 KV Projects) in turnkey contracts and for participation in tenders for these items floated by PTCUL provided your company meets the PQR criteria of the respective floated tender. Your vendor registration has been accepted with following conditions:

1. Company will have to follow the rules and regulation laid down by PTCUL.
2. Company has to get the approval of MQP before commencement of their production and QAP before placing inspection call for supply of material.
3. This acceptance does not absolve you from your contractual liabilities of the respective tender.
4. The material to be supplied has to be type tested for its design and type test report of each type of cables shall have to be submitted in PTCUL before commencement of production.
5. Source of the raw material has to be got approved by PTCUL before manufacturing of the cable.

(Anil Kumar)

Superintending Engineer (QA/QC)

No. /SE(QA/QC)/PTCUL/

Dated:-16/08/2012.

Copy forwarded for kind information.

1. SE (Engg.), PTCUL H/Q Building, 132 KV S/s Majra, Dehradun.

(Anil Kumar)

Superintending Engineer (QA/QC)